

Noise Performance of the Debuncher Stochastic Cooling Systems

A careful measurement of the system noise performance for all 12 Debuncher stochastic cooling systems has been performed. The opportunity to make the measurement was due to a pickup tank warm up to fix a bad preamplifier. A HP power meter and spectrum analyzer were used to measure the noise power and spectral characteristics of each system. Signals were monitored in the tunnel at the medium level transfer switch, before any variable gain devices. Noise power levels observed ranged between -10 to -30 dBm, which is well within the linear calibration range of the power meter. The noise floor of the power meter was measured to be below -40 dBm.

The temperature of the tunnel for the warm measurements was 80 degrees F or 300 Kelvin. The tanks had been at tunnel temperature for weeks when the warm measurement was made. There was no vacuum in the tanks for the warm measurement. The cold temperature of the tanks at liquid helium was 4.5-5 K. 5K was used in the calculations. No component changes were made between the measurements.

The gain of the cryogenic amplifier increases with a decrease in operating temperature. The gain of the cryo amplifier was carefully measured both warm and cold so that this change could be taken into account.

The Noise Figure in dB and effective noise temperature are derived from the equations below. $T_2 - T_1$ is the difference in operation temperature in degrees Kelvin, in this case 300-5 or 295 deg. K. Y is the excess noise ratio, which is measured in dB by the power meter by taking the difference in noise power between warm and cold measurements. This log value must be converted to linear for use in this equation. The value for Y is also corrected for the increase in gain due to the change in the operating temperature of the amplifier. This data was derived from the warm and cold preamp temperatures measured in the tunnel. The noise figure NF used in the effective noise temperature equation must also be converted to linear. Except for two systems where noise was measured to be below reasonable levels (in red on spreadsheet), the numbers appear to be reasonable.

$$\text{EffectiveNoiseTemperature(degK)} = 290 * (\text{NF} - 1)$$

$$\text{NoiseFigure(dB)} = 10 * \text{Log}\left(\frac{T_2 - T_1 * Y}{290 * (Y - 1)} + 1\right)$$

Debuncher Pickup Noise Performance

	Band 1						Band 2						Band 3						Band 4											
	dBm		dB		degK		dBm		dB		degK		dBm		dB		degK		dBm		dB		degK							
	Warm	Cold	delta G	Y	NF	Teff	Warm	Cold	delta G	Y	NF	Teff	Warm	Cold	delta G	Y	NF	Teff	Warm	Cold	delta G	Y	NF	Teff						
Mom																														
PHL	-23.29	-30.82	5.10	12.63	0.18	12	-23.28	-29.18	5.80	11.70	0.24	16	-25.28	-37.10	5.70	17.52	0.00	0	-23.60	-28.25	6.00	10.65	0.33	23						
PHU	-16.39	-24.15	4.70	12.46	0.19	13	-25.48	-31.80	5.50	11.82	0.23	16	-21.88	-25.70	5.00	8.82	0.56	40	-23.08	-27.88	6.00	10.80	0.31	22						
PVL	-21.69	-29.07	4.60	11.98	0.22	15	-19.57	-26.20	5.00	11.63	0.24	17	-22.65	-35.80	6.20	19.35	-0.02	-2	-23.70	-28.61	5.00	9.91	0.41	29						
PVU	-17.59	-25.43	5.40	13.24	0.14	10	-24.68	-29.93	5.30	10.55	0.34	24	-23.33	-30.40	3.00	10.07	0.39	27	-23.08	-28.68	5.00	10.60	0.33	23						
all 4	-12.86	-20.61					-16.60	-22.89					-17.30	-24.18					-17.57	-22.57										
Horiz																														
HL	-15.92	-24.95	4.80	13.83	0.11	8	-20.05	-27.65	4.90	12.50	0.18	13	-24.05	-28.15	5.00	9.10	0.51	36	-19.05	-23.98	5.00	9.93	0.41	28						
HU	-17.40	-24.44	3.90	10.94	0.30	21	-22.39	-28.44	5.80	11.85	0.23	16	-18.44	-23.60	6.00	11.16	0.28	19	-20.16	-25.66	6.00	11.50	0.25	17						
both	-13.59	-21.70					-18.03	-25.15					-17.46	-22.33					-16.63	-21.80										
Vert																														
VL	-15.38	-23.57	4.40	12.59	0.18	12	-19.33	-25.40	3.70	9.77	0.42	30	-19.18	-24.29	3.50	8.61	0.59	42	-18.78	-23.05	4.00	8.27	0.65	47						
VU	-15.50	-24.20	4.10	12.80	0.17	11	-18.22	-24.92	5.10	11.80	0.23	16	-19.42	-24.22	4.80	9.60	0.45	31	-20.25	-25.90	5.00	10.65	0.33	23						
both	-12.43	-20.92					-15.74	-22.23					-16.35	-24.25					-16.52	-21.30										

NOTES

Warm temperature of the tunnel on 2/23/01 was 80 degrees F which is 300 degrees Kelvin

Cold pickup temperature is taken as 5 degrees Kelvin.

Noise floor of power meter -42 dBm

Measurements taken at eight way switch where all transfer switches are connected. No cable used on power meter

Spectrum analyzer was used to check spectrums.

All pads were same for both warm and cold measurements.

Warm and cold measurements in dBm are noise power as measured on the power meter

Y factor and NF are in dB

Teff is degrees Kelvin

delta G is the gain change in the cryo amp at liquid helium temperature as measured on the injection to output on the flange.

Band 3 momentum horiz and vertical lower had an excessively low cold power reading. These noise figures are not reliable.

All cryo amplifiers are Miteq AMF CRYO series

